From: Andrew Jurrius

To: Umar Mahmood; Jennifer Larmer
Subject: Re: 932 Isaac Phillips Way
Date: July 8, 2024 4:31:23 PM
Attachments: image924630.png

The minimum landing size at the bottom of a stair is 900mm x 900mm (3 feet x 3 feet). I also noticed that the property water shut-off is in the area that they wish to pave. Andrew

Andrew Jurrius

Chief Building Official | Planning & Building Services
Town of Newmarket | 905-953-5300 x2402 | ajurrius@newmarket.ca

Note: Our working hours may be different. Please do not feel obligated to reply outside of your scheduled working hours.

From: Umar Mahmood <umahmood@newmarket.ca>

Sent: Monday, July 8, 2024 3:57:40 PM

To: Jennifer Larmer < jlarmer@newmarket.ca> **Cc:** Andrew Jurrius < a jurrius@newmarket.ca>

Subject: 932 Isaac Phillips Way

Hi Jenn,

We have minor variance application going to hearing on July 31 for a driveway widening in front of a porch. Is there any OBC requirement for the landing?

Thank you.

Regards, Umar



Umar Mahmood

Planner COA & Cultural Heritage | Planning & Building Services 905-953-5300 x2458 | umahmood@newmarket.ca | heynewmarket.ca Follow us on X, Facebook and Instagram Newmarket: A Community Well Beyond the Ordinary

Note: Our working hours may be different. Please do not feel obligated to reply outside of your scheduled working hours.

The information contained in this message is directed in confidence solely to the person(s) named above and may not be otherwise distributed, copied or disclosed. The message may contain information that is privileged, confidential and exempt from disclosure under the *Municipal Freedom of Information and Protection of Privacy Act*. If you have received this message in error, please notify the sender immediately advising of the error and delete the message without making a copy. Thank you.